

## Power flow analysis with TCSC using Newton- Raphson method

Mukesh Kumar Gupta  
Mugupta72@gmail.com  
M.Tech Guide  
Assistant prof. in EE deptt.  
Jagannath University  
Jaipur

Pardeep rana  
pranarohtak@gmail.com  
M.Tech Scholar  
Jagannath University  
Jaipur

**Abstract:** - In this paper, Newton Raphson power flow algorithm in matlab incorporating TCSC is presented. Overview of the different static load models for distribution system has been covered and included in N-R power flow. This paper present effect of TCSC level on transmission system voltage profile for different types of static load types , in which active and reactive power vary with its terminal voltages with as in exponential form, variation of the load voltage for different sizes of TCSC are simulated with 3 bus . It has also been observed that the proposed algorithm can be applied to larger systems and does not suffer with computational difficulties

\*\*\*\*\*

### 1. INTRODUCTION:

When large power systems are interconnected by relatively weak tie lines, low frequency oscillations are observed. These oscillations may sustain and grow to cause system separation if no adequate damping is available .Recent development of power electronics introduces the use of flexible ac transmission system (FACTS) controllers in power systems. FACTS controllers are capable of controlling the network condition in a very fast manner and this feature of FACTS can be exploited to improve the stability of a power System .Thyristor Controlled Series Compensator (TCSC) is one of the important members of FACTS family that is increasingly applied with long transmission lines by the utilities in modern power systems. It can have various roles in the operation and control of power systems, such as scheduling power flow; decreasing unsymmetrical components; reducing net loss; providing voltage support limiting short-circuit currents; mitigating sub-synchronous resonance (SSR); damping the power oscillation; and enhancing transient stability . The problem of FACTS controller parameter tuning is a complex exercise as uncoordinated local control of FACTS controller may cause destabilizing interactions[4] . The demand of electrical power is ever increasing. However, the process of development of new infrastructure for power generation and dispatch is restricted due to mainly economic and partially environmental constraints. These result in the need for better utilization of the existing system. Flexible AC transmission system (FACTS) controllers are potent tools to achieve this goal. These devices help in pushing the system to their limits and thus to attain higher operational efficiency. The use of these controllers increases the flexibility of operation by providing more options to the power system operators.[5]

### 2.TCSC(Thyristor controlled series capacitor):

The configuration of TCSC is shown in *Figure 1*. TCSC configuration uses the thyristor –controlled

reactors (TCR's) is parallel with a segment of a capacitor bank. This configuration allows the fundamental frequency capacitive reactance to be smoothly controlled over a wide range and switch to a condition where the bi-directional thyristor pairs conduct continuously and insert an inductive reactance in the line.

D1 and D2 are high power diode

L= Air cored inductor (few mH)

MOV = Metal oxide Varistor provided across the capacitor to prevent the over voltage across the capacitor.

Capacitor bank may have the reactance of 10-30  $\Omega$ /Ph and rated for continuous current 1500-3000 A rms. The capacitor bank for each phase mounted on a platform providing full insulation towards ground.[1]




Figure 1. Thyristor Controlled Series Capacitor  
**3. POWER FLOW ANALYSIS WITH TCSC:**

Power flow or Load flow is the solution obtained for power system under the static condition of operations, the load flows studies are carried out to determine :-[4]

i)line losses

- ii) The bus voltages and the system voltage profiles
- iii) The effect of the changes in the circuit configuration and incorporating new circuits on system loading
- iv) The effect of temporary loss of transmission capacity and (or) generation on the system loading and accompanied factor
- v) The effect of in phase and quadrature boost voltage on the system loading
- vi) Economic operation system
- vii) System transmission loss minimization
- viii) Transfer for tap setting operation
- ix) Possible improvement to the existing system by changing load configuration or system voltages

**4.Power Flow Problem**

Power flow studies are performed to calculate the magnitude of phase angles of voltages at the buses and also the active power and reactive VA flow for the given terminal or bus conditions. The following variables associate with each bus:-[18]-[21]


- i) Magnitude of voltage  $|V_i|$
  - ii) Phase angle of voltages  $\delta_i$
  - iii) Active power  $P_i$  and
  - iv) Reactive VA  $Q_i$
- There are three types of buses used in power flows studies. At each bus two variables are specified

∴

:

**CASE-1 –THREE BUS SYSTEM**

A 3-bus system as shown in Figure 5.1 below has been considered. The system parameters are given in Table – 4 and Load and



**Fig:2 Three Bus System**

**TABLE – 2**

Three Bus System Parameters

and two are to be determined. The bus classifications depend upon the specified variable. The buses are classified as –

S. No.	Bus Type	Specified Variable	Unknown Variable	Remarks
1	Slack Bus	$V_i, \delta_i$	$P_i, Q_i$	First responds to a changing load conditions
2	Generator Bus	$P_i, V_i$	$\delta_i, Q_i$	Often upper and lower limits of Q are given.
3	Load Bus	$P_i, Q_i$	$V_i, \delta_i$	Buses with no generator but load is considered as load bus

**5.PROBLEM FORMULATION AND RESULT:**

Power Flow Analysis using TCSC has been undertaken for two different cases i.e Case – 1 – A Three Bus System and Case– 2 – A Five Bus System presented hereunder:

Generation data are as presented in Table -5. The bus voltage at bus 2 is maintained at 1.03 p.u.. The maximum and minimum reactive

power limits of generator bus 2 are 0.35p.u. and 0.0 p.u respectively. Bus 1 is taken as slack bus.

Bus Code	Impedance (p.u.)	Line Charging Admittance (pu)
1-2	0.08+j0.24	0
1-3	0.02+j0.06	0
2-3	0.06+j0.18	0

**TABLE – 3**

Scheduled Generation / Load / Voltages

Bus Number	Bus Voltage	Generation (p. u)		Load (p.u.)
		MW	MW	MVar
1	1.05	0	0	0
2	1.03	0	0.3	0.3
3	-	0	0.6	0.25

**RESULT:**

For the TCSC parameter let the capacitance offer the reactance of  $-0.12\text{p.u.}$ . In the thyristor arm let the firing angle  $\alpha = 150.0$  degree which regulates the inductive reactance in this arm. To compute the reactance of inductance the load flow has been done for getting optimal flow in compensated line. The result is given below when each line is compensated by same amount respectively.

Each line is compensated by amount of  $0.04 \text{ p.u.}$ . Capacitive reactance of TCSC  $X_{\text{TCSC}} = -0.04 \text{ p.u.}$

**CASE 1.1**

The bus admittance matrix with ground as reference for the given three-bus system with TCSC in line 1(bus1-2) is given by:




Fig-3




Fig-4

**Case 1.2**

In this case TCSC is installed in line 2(1-3)

The bus admittance matrix with ground as reference for the given three-bus system with TCSC in line 2(1-3) is given by:




Fig-5

Above figure- 5 shows the variation of power flow after TCSC has been installed on line2 (bus1-3). The maximum power flow has been on line 2(bus1-3)& line3(bus2-3). Line2 (1-3) power capability has been increased using TCSC in line 2(1-3). Figure -6 shows the line losses of different lines after TCSC has been installed on line 2(1-3). The maximum losses are in line2 (1-3) as current carrying capability has been increased.




Fig-6

**Case 1.3**

In this case TCSC is installed in line3(2-3)

The bus admittance matrix with ground as reference for the given three-bus system with TCSC in line 3(2-3) is given by:




Fig-7

Above figure -7 shows the variation of power flow after TCSC has been installed on line3 (bus2-3).. Figure -8 shows the line losses of different lines after TCSC has been installed on line 3 (2-3)




Fig-8

## Discussions and Conclusion

The motivation of this paper is to develop an algorithm in matlab to choose the location of FACTS devices – TCSC Thyristor Control Series Capacitor to maximize the power flow in a given power network based on load flow studies using Newton Raphson method. The main purpose of load flow a study is to analyze in which line TCSC should be installed so that the overall power flow capacity of transmission line is increased. This attempt has been made in Chapter 4 – “Power Flow Analysis with TCSC” in which power flow model with TCSC has been designed.

To validate this analysis two case studies have been taken up. Case -1 is for 3 bus system and Case - 2 is for 5 bus system

## REFERENCES:

1. Newton Raphson TCSC Model For Power Flow Solution of Practical Power Networks - Abdel Moamem M.A. & Narayana Prasad Padhy.
2. Multi Objective Optimal Power Flow Model with TCSC for Practical Power Networks - Abdel Moamen M K & Naryana Prasad Padhy.
3. Thyristor Controlled Series Compensator Model for Power Flow Solution of Practical Power Network - C.R. Fuerte Esquivel, Acha & H. Ambriz Peraz. IEEE transactions on Power Systems, vol. 15, No. 1, Feb 2000.
4. Power system stability improvement by tsc controller employing a multi-objective genetic algorithm approach- Siddhartha panda, r.n.patel, n.p.padhy

5. Enhancement of power flow using TCSC controller- p paul clec, SVL narasimham.
6. Flexible AC Transmission System - A Case Study - Ramesh Bahri, K.R. Suri, Rajesh Kumar, Rajil Srivastava
7. A Flexible Software Environment for Steady State Power Flow Optimization with Series FACTS Devices - Tna Orfanogianni , Swiss Federal Institute of Technology, Zurich.
8. Using Facts Controllers to Maximize Available Transfer Capability Bank Power Systems Dynamics and Control - Claudio A. Canizares, Alberto Berizzi, Paolo Marannino IV. Restructuring, August 24-28, 1998, Santorini, Greece.
9. Reactance Power Management - D.M. Tagare, Tata Mcgraw-Hill Publication copyright 2004.
10. SSR Study for the Thyristor Controlled Series Compensation Application on the Kanpur-Ballabgarh 400KV in Dudina - Sujatha Subhash, A.K. Tripathy, KR Padiyar, Satish Nayyar, Manoj Kumar, PJ Thakkar and KK Arya.
11. Power Flow Control and Power Flow Studies for System with Studies Douglas J. Gotham & G.T. Heydt – IEEE transaction on power system, vol. 13 No. 1 Feb 1998.
12. Improving System Static Security Via Optimal Placement of TCSC - Yungiang Lu and Ali Abur – 2001 IEEE.
13. Thyristor Controlled Series Compensable Application Study Control Interaction Consideration - K. Clark, B. Fardanesh & R Ada — IEEE Transaction on Power Delivery, Vol. 10 No.2, April 1995.
14. Determination of Needed Facts Controller that Increase Asset Utilization of Power System - L.A.S. Pilotto, W. W. Ping, Carvallho, Wey, Long and Edris - IEEE transaction on power delivery vol. 12 No. 1, January 1997.
15. FACTS Modeling And Sunatation In Power Network - Enrique, Claudio R. Fuerte-Esquivel, Ambriz – Perez –John Wiley & Sons Ltd2004.
16. "Thyristor-Based FACTS Controllers for Electrical Transmission Systems", R.Mohan Mathur and Rajiv K. Verma, , IEEE Press and Wiley
17. Reactive Power Control In Electric System - T.J.E. Miller – A Wiley Interscience publication New York 1982.
18. Power System Analysis - Hadi Saadat , Tata MC Graw Hill, Edition 2002.
19. Power System Stability And Control - Prabha Kundur, Tata Mc Graw Hill Edition 2006.
20. Electric Power Systems – C.L. Wadhwa , New Age International, Edition 2003
21. Computer Methods and Power System Analysis- W. G. Stagg and Ahmed Albiad